

# Certificate of Suitability

Global-Mark Pty. Ltd., certify the electrical equipment described hereunder complies with standards listed herein and notifies the certificate holder to affix the Regulatory Compliance Mark (RCM) mark on the product of the same type provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled. In placing the RCM mark on the product, the Responsible Supplier makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. This Certificate meets the requirements of a Recognised External Certification Scheme (RECS).

## CERTIFICATION AND CERTIFICATE HOLDER DETAILS

Company Name	<b>TCI Telecomunicazioni Italia S.R.L.</b>	Other Name	
Address	<b>Via Parma 14, Cap Saronno Varese 21047 Italy</b>		
Client ID	<b>105895</b>	Global-Mark File Number:	<b>105895-068</b>
Certification Number	<b>GMA-519994</b>	Revision Number	<b>00</b>
Certificate Standard(s)	<b>AS 61347.2.13:2018 &amp; AS/NZS 61347.1:2016 + A1 Lamp Control Gear - Part 2-13: Particular Requirements For D.C Or A.C Supplied Electronic Control Gear For Led Modules.</b>		
Type of Certification	<b>Electrical Safety Product</b>	Scheme	<b>Global-Mark Electrical Product Safety Certification Scheme</b>

System 1 Approval

## CERTIFICATE DATES

Certificate Issue Date	<b>30/08/2024</b>
Certificate Last Update Date	
Certification Expiry Date	<b>30/08/2029</b>

This certification remains valid until the above-mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to [www.jasanz.org/register](http://www.jasanz.org/register) for verification.



Certification Manager



# Certificate of Suitability

CERTIFIED ELECTRICAL EQUIPMENT				
Declared Article	Product Description	Trade Name	Model Number	Rating
Non declared	Electronic controlgear for LED modules (Electronic Converter for LED)	TCI LED	PROFESSIONALE ECO 14W	Input: 220-240Vac, 50/60Hz, 0.065-0.08A; Output: 6-20Vdc, Uout: 60Vdc, 0.35-0.7A, 14W; ta.-20...45°C, tc.75°C, 110oC thermally protected, Built-in (double/reinforce insulation)
Non declared	Electronic controlgear for LED modules (Electronic Converter for LED)	TCI LED	PROFESSIONALE ECO 17W	Input: 220-240Vac, 50/60Hz, 0.08-0.095A; Output: 20-42Vdc, Uout: 60Vdc, 0.25-0.4A, 16.8W; ta.-20...45°C, tc.70°C, 110oC thermally protected, Built-in (double/reinforce insulation)
Non declared	Electronic controlgear for LED modules (Electronic Converter for LED)	TCI LED	PROFESSIONALE ECO 25W	Input: 220-240Vac, 50/60Hz, 0.12-0.14A; Output: 20-42Vdc, Uout: 60Vdc, 0.45-0.6A, 25.2W; ta.-20...45°C, tc.80°C, 110oC thermally protected, Built-in (double/reinforce insulation)
Non declared	Electronic controlgear for LED modules (Electronic Converter for LED)	TCI LED	PROFESSIONALE ECO 33W	Input: 220-240Vac, 50/60Hz, 0.16-0.18A; Output: 20-42Vdc, Uout: 60Vdc, 0.65-0.8A, 33.6W; ta.-20...45°C, tc.80°C, 110oC thermally protected, Built-in (double/reinforce insulation)
Non declared	Electronic controlgear for LED modules (Electronic Converter for LED)	TCI LED	PROFESSIONALE ECO 25W 145156ASN	Input: 220-240Vac, 50/60Hz, 0.12-0.14A; Output: 20-42Vdc, Uout: 60Vdc, 0.45-0.6A, 25.2W; ta.-20...35°C, tc.80°C, 110oC thermally protected, Built-in (double/reinforce insulation)
Non declared	Electronic controlgear for LED modules (Electronic Converter for LED)	TCI LED	PROFESSIONALE ECO 33W 145157ASN	Input: 220-240Vac, 50/60Hz, 0.16-0.18A; Output: 20-42Vdc, Uout: 60Vdc, 0.65-0.8A, 33.6W; ta.-20...35°C, tc.80°C, 110oC thermally protected, Built-in (double/reinforce insulation)

This certification remains valid until the above-mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to [www.jasanz.org/register](http://www.jasanz.org/register) for verification.



**Certification Manager**



# Certificate of Suitability

Non declared	Electronic controlgear for LED modules (Electronic Converter for LED)	TCI LED	PROFESSIONALE ECO 40W	Input: 220-240Vac, 50/60Hz, 0.18-0.215A; Output: 30-50Vdc, Uout: 60Vdc, 0.5-0.8A, 40W; ta.-20...45°C, tc.80°C, 110oC thermally protected, Built-in (double/reinforce insulation)
Non declared	Electronic controlgear for LED modules (Electronic Converter for LED)	TCI LED	PROFESSIONALE ECO 44W	Input: 220-240Vac, 50/60Hz, 0.21-0.24A; Output: 20-42Vdc, Uout: 60Vdc, 0.9-1.05A, 44.1W; ta.-20...45°C, tc.85°C, 110oC thermally protected, Built-in (double/reinforce insulation)

## RELEVANT TRADEMARK (S)



## COMMENTS OR CONDITIONS ON THE CERTIFICATION

Nil

End of document

This certification remains valid until the above-mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to [www.jasanz.org/register](http://www.jasanz.org/register) for verification.



Certification Manager



Page 3 of 3

