



Reference No. SE-S-2400061

Junction box

**Type designation:** 5665, 5660/2, 5663

**Certificate holder:** STEAB S.r.l.

Via G. Marconi 1/3

Scopeti, IT-50068 Rufina (FI) Italy

The product complies with

the standard(s):

EN 60998-2-1:2004

**Date of expiry:** 16 January, 2029

**EU Directive information:** According to the principle of presumption of conformity, this certificate

constitutes support for an EU Declaration of Conformity to the Low

Voltage Directive 2014/35/EU.

Additional informatio	n in Appendix		
Certification Body:	Intertek Semko AB, Product Certification	Place:	Kista - Stockholm
Signed:	anan Li		16 January, 2024
	Quan Li		

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Intertek Semko AB Page 1 of 3



## **APPENDIX:**

Reference No. SE-S-2400061

## **Technical Data:**

Type designation 5665
Rated voltage (V) 250V AC
Rated current (A) 6 A

IP-Class IP68 (1,3 m)

Number of terminals 2

Rated connecting cap 0,75 mm<sup>2</sup>
Trademark STEAB

Test Report 2307547STO-001

Product information For 2 cables Ø4,8-6,0 mm

Type designation 5660/2
Rated voltage (V) 450V AC
Rated current (A) 25 A

IP-Class IP68 (1,3 m)

Number of terminals 2
Rated connecting cap 6 mm<sup>2</sup>
Trademark STEAB

Test Report 2307547STO-002

Product information For 2 cables Ø7,5-16,0 mm

Type designation 5663
Rated voltage (V) 450V AC
Rated current (A) 25 A

IP-Class IP68 (1,3 m)

Number of terminals 3

Rated connecting cap  $6 \text{ mm}^2 / 2.5 \text{ mm}^2$ 

Trademark STEAB

Test Report 2307547STO-003

Product information For 2 cables of  $\emptyset$ 7,5-16,0 mm + 1 tapping cable of  $\emptyset$ 6,5-12,0 mm.



Intertek Semko AB Page 2 of 3



## **APPENDIX:**

Reference No. SE-S-2400061

Manufacturing Sites:	STEAB S.r.l. Via G. Marconi, 1/3 Scopeti Rufina (FI)IT-50068 Italy		
A gooding to the university		try this coutificate which	in allu dan muo du ati an ao utura l
	of presumption of conformation of Conformation of Conformation of Conformation of Conformation of Conformatical Co		
This presumption can exp Amendment and changes	ire before end of validity of within the EU legislation.	this certificate due to new	issued Standard or
	reviously issued S-certificaton issued on account of renew		ated 8 October 2018.
Certification Body:	Intertek Semko AB, Product	Certification Place:	Kista - Stockholm
Signed:	Qual.	Date:	16 January, 2024

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Quan Li

Intertek Semko AB Page 3 of 3