

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	LED driver
Name and address of the applicant	TCI Telecomunicazioni Italia Srl Via Parma 14, 21047 Saronno (VA), Italy
Name and address of the manufacturer	TCI Telecomunicazioni Italia Srl Via Parma 14, 21047 Saronno (VA), Italy
Name and address of the factory	<input checked="" type="checkbox"/> Additional information on page 2 Taiwan Surface Mounting Technology (SuZhou) Co., Ltd. No. 888 GanQuan Dong Road, Economic Technology Development Zone, WuJiang, Suzhou, China
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	ECO 27/600-650: PRI: 220-240 Vac; fn: 50/60 Hz; In: 0,14/0,15 A; Pn: 29/31 W; PF: 0,92C; SEC: 30-42 Vdc; Uout: 60 Vdc; Io: 0,6/0,65 A; Po: 25,2/27 W; tc: 80 °C; Independent; SELV ECO 32/700-750: PRI: 220-240 Vac; fn: 50/60 Hz; In: 0,16/0,17 A; Pn: 33/36 W; PF: 0,92C; SEC: 30-42 Vdc; Uout: 60 Vdc; Io: 0,7/0,75 A; Po: 29,4/32 W; tc: 80 °C; Independent; SELV ECO 36/800-850: PRI: 220-240 Vac; fn: 50/60 Hz; In: 0,18/0,19 A; Pn: 38/41 W; PF: 0,92C; SEC: 30-42 Vdc; Uout: 60 Vdc; Io: 0,8/0,85 A; Po: 33,6/36 W; tc: 80 °C; Independent; SELV ECO 40/900-950: PRI: 220-240 Vac; fn: 50/60 Hz; In: 0,2/0,21 A; Pn: 43/45 W; PF: 0,92C; SEC: 30-42 Vdc; Uout: 60 Vdc; Io: 0,9/0,95A; Po: 37,8/40 W; tc: 80 °C; Independent; SELV ECO 44/1000-1050: PRI: 220-240 Vac; fn: 50/60 Hz; In: 0,22/0,23 A; Pn: 47-50 W; PF: 0,92C; SEC: 30-42 Vdc; Uout: 60 Vdc; Io: 1/1,05 A; Po: 42-44 W; tc: 80 °C; Independent; SELV
Trademark (if any)	TCI
Customer's Testing Facility (CTF) Stage used	CTF Stage 3

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands



IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Model / Type Ref.	ECO 27/600-650 ECO 32/700-750 ECO 36/800-850 ECO 40/900-950 ECO 44/1000-1050
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60598-1:2014, IEC 60598-1:2014/AMD1:2017, IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016, IEC 62384:2006, IEC 62384:2006/AMD1:2009 National differences: EU Group Differences
As shown in the Test Report Ref. No. which forms part of this Certificate	6076466.50 and 6076466.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands



IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Additional factory

Hengdian Group Tospo Lighting Co., Ltd.
Hengdian Industrial Zone,
322118 Dongyang City,
Jinhua, Zhejiang Province,
China

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2020-06-15

Signature: Kate Xu

A handwritten signature in black ink, appearing to read "Kate Xu", written over the printed name.