



CERTIFICATE

FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2100709

Junction box for use in luminaires

Type designation: 5593

Certificate holder: STEAB S.r.l.
Via G. Marconi 1/3 Loc. Scopeti
IT 50068 Rufina (FI)
ITALY

The product complies with the standard(s): EN 60598-1:2015+A1

Date of expiry: 19 March, 2024

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed:


Leif Mattsson

Date: 19 May, 2021

APPENDIX:

Reference No. SE-S-2100709

Technical Data:

Type designation	5593
Rated voltage (V)	250
Rated current (A)	4
Conductor area	1,5 mm ²
Number of terminals	3
Trademark	STEAB 
Test Report	2103366STO-001
Product information	Junction box for use in luminaires, made of white plastic (Nylon 66 AE). Glow wire 850°C resistant. T 110.

For cable in ingoing opening:

- With sleeve and 3 single insulated cables max 1,5 mm²
- Without sleeve and double insulated cable H03 / H05 (Max Ø 6,5 mm)

For cable in outgoing opening:

- Double insulated cable H03 / H05 (Max Ø 6,5 mm)

Safety related parts of the user instructions shall be written in a language acceptable to the country where the product is to be used.

Manufacturing Sites:

STEAB S.r.l.
Via G Marconi, 1/3
P.I.P. Scopeti
IT-50068 RUFINA (FI)
ITALY

Certification Body:

Intertek Semko AB, Product Certification

Place:

Kista - Stockholm

Signed:



Leif Mattsson

Date:

19 May, 2021